

FIGURE 1




FIGURE 2

**Honeywell**  
T7350 Configuration Tool  
Version: 0.0.d.18d

Override Monitor Data  
Set Clock Holidays  
Temp SetPts Wkly Schedule  
Upload Config  
New Config

▼ Select Existing Config

FIGURE 3a

**Summary** ▼ Select Setup

**C nfig Name:** New Config  
**Description:**  
120 character description which is.....  
user entered.....

**Model:** ▼ Mod1\_Basic  
**Control:** Standard Heat Pmp  
**Cnfig ID:** 00

DownLd  
Back Next Save SaveAs

FIGURE 3b

**Honeywell**  
T7350  
Configuration Tool  
Version: 0.0.d.5

Temp SetPts Holidays  
Set Clock Wkly Schedule  
Monitor Data Upload Config  
New Config

▼ Select Existing Config

FIGURE 4a

**Honeywell**  
T7350  
Configuration Tool

DEFAULT  
Example1  
Example2  
Example3  
Example4  
New Config

Holidays  
Schedule  
d Config

FIGURE 4b

**Summary**

**C nfig Name:** Example2  
**Description:**  
T7350B model supports: 6 relays.....  
remote space sensor, DAT, OAT.....

**Model:** ▼ T7350B (6DigOut)  
**C ntrl:** Standard Heat Pmp  
**Cnfig ID:** 22

DownLd  
Back Next Save SaveAs

FIGURE 4c

**Summary**

**Config Name:** Example2  
**Description:**  
T7350B model supports: 6 relays.....  
remote space sensor, DAT, OAT.....

**Connecting to T7350**

**Please connect PDA  
serial port to the T7350  
using serial cable.**

OK Cancel

FIGURE 4d

**Honeywell**  
T7350 Configuration Tool  
Version: 0.0.d.18d

Override Monitor Data

Set Clock Holidays

Temp SetPts Wkly Schedule

Upload Config

New Config .....

▼ Select Existing Config

FIGURE 5a

**Summary** ▼ Select Setup

**Config Name:** New Config  
**Description:**  
120 character description which is.....  
user entered.....

**Model:** ▼ Mod1\_Basic  
**Control:** Standard Heat Pmp  
**Cnfg ID:** 00

DownLd

Back Next Save SaveAs

FIGURE 5b

**Summary**

**Config Name:** New Config  
**Description:**  
.....  
.....  
.....

**Connecting to T7350**

**Please connect PDA  
serial port to the T7350  
using serial cable.**

OK Cancel

FIGURE 5c

**Honeywell**  
T7350 Configuration Tool  
Version: 0.0.d.18d

Override Monitor Data

Set Clock Holidays

Temp SetPts Wkly Schedule

Upload Config

New Config .....

▼ Select Existing Config

FIGURE 6a

**Honeywell**  
T7350  
Configuration Tool  
Version: 0.0.d.5

Temp SetPts Wkly Schedule

**Connecting to T7350**

**Please connect PDA  
serial port to the T7350  
using serial cable.**

OK Cancel

FIGURE 6b

**Summary** ▼ Select Setup

**Config Name:** XYZ  
**Description:**  
Customer XYZ summary.....  
information.....

**Model:** ▼ Mod1\_Basic  
**Control:** Standard Heat Pmp  
**Cnfg ID:** 00

DownLd

Back Next Save SaveAs

FIGURE 6c

Summary	
<b>Config Name:</b>	XYZ
<b>Description:</b>	A short description of customer XYZ configuration.
<div> <div>Connecting to T7350</div> <div> <div></div> <div>Please connect PDA serial port to the T7350 using serial cable.</div> </div> <div> <div>OK</div> <div>Cancel</div> </div> </div>	

FIGURE 6d

File	Connect	Setup	Help
Conf	Download	tomer XYZ	
Desc	Upload	ption.....	
120 d	Monitor	.....	
	Set Clock		
	Calibrate		
<div> <div>Model:</div> <div>Control:</div> </div>			
<div>Down Load</div>		<div>Save As</div>	
<div>Next</div>		<div>Save</div>	

FIGURE 7a

Room Temp Calibrate	
<b>Actual Value:</b>	68.4 F
<b>Edit Value:</b>	68.4  F
<b>Offset:</b>	-3 F
<div> <div>Calibrate</div> <div>Refresh</div> <div>Close</div> </div>	

Figure 7b

Honeywell	
T7350 Configuration Tool	
Version: 0.0.d.18d	
<div>Override</div>	<div>Monitor Data</div>
<div>Set Clock</div>	<div>Holidays</div>
<div>Temp SetPts</div>	<div>Wkly Schedule</div>
<div>Upload Config</div>	
<div>New Config</div>	
<div>▼ Select Existing Config</div>	

FIGURE 7a

Honeywell	
T7350	
Configuration Tool	
Version: 0.0.d.5	
<div> <div>Connecting to T7350</div> <div> <div></div> <div>Please connect PDA serial port to the T7350 using serial cable.</div> </div> <div> <div>OK</div> <div>Cancel</div> </div> </div>	

FIGURE 8b

Summary	
<b>Config Name:</b> U04/09/03 11:05	
<b>Description:</b>	
Upload: 04/09/2003, 11:05 am	
FrmwrV: 0.0.14, ComV: 1002	
rePrgrV: 1, SubBaselD: 3	
<b>Model:</b> ▼ T7350D,3H3C,RH	
<b>Control:</b> <b>Standard</b> Heat Pmp	
CnfgID	
DownLd	
Back	Next
Save	SaveAs

FIGURE 8c

Honeywell	
T7350 Configuration Tool	
Version: 0.0.d.18d	
Override	Monitor Data
Set Clock	Holidays
Temp SetPts	Wkly Schedule
Upload Config	
New Config	
▼ Select Existing Config	

FIGURE 8d

Monitor Data	
SubBaselD: T7350D,3H3C,RH	
FirmwareVersion: 0.0.19	
=====	
RoomTemperature:	79.2 F
EffectiveSetPoint:	75.0 F
=====	
RoomRH:	31 %
Dehumidification:	Off
=====	
DischargeAirTemp:	70.3 F
Update	
Close	

Figure 8e

Summary	
<b>Config Name:</b> Example3	
<b>Description:</b>	
T7350C SmartStat supports: 6	
Relays, remote space sensor, DAT,	
OAT, RH, Occ sensor	
<b>Model:</b> ▼ T7350C (6DigOut+RH)	
<b>Control:</b> <b>Standard</b> Heat Pmp	
Cnfg ID: 23	
DownLd	
Back	Next
Save	SaveAs

Figure 9a

Inputs	
<b>RoomTemp:</b>	<b>Local</b> Remote
	Rmt+StPt
<b>Room</b>	<b>Local</b> Remote
<b>Rel Humidity:</b>	None
<b>Occ Sensor:</b>	None Remote
<b>Discharge</b>	
<b>AirTemp:</b>	None Remote
<b>Outdoor</b>	None Remote
<b>AirTemp:</b>	
Back	Next

FIGURE 8b

Outputs	
<b>AuxDO:</b>	<b>Time of Day</b>
	Economizer
	Dehumid Hot Gas BP
	Simple Dehumid
Back	Next

FIGURE 9c

**Cooling Config**

Stages: 0 1 2 3

Cooling: Std 3 cph

Response: Fast 4 cph

☒ Enable OAT Lockout  
OAT SetPt 35 F

☒ Enable DAT Low Limit  
DAT SetPt 45 F

Back Next

FIGURE 9d

**Heating Config**

Stages: 0 1 2 3

Heating: Std 3cph Med 6cph

Response: Fast 9cph Fast!!20cph

☒ Enable OAT Lockout  
OAT SetPt 70 F

☒ Enable DAT High Limit  
DAT SetPt 110 F

Back Next

FIGURE 9e

**Fan**

FanSwitch: On Auto

FanOperation: Conventional Electric Heat

Heat: No Extended Op Extend 90 sec

Cool: No Extended Op Extend 90 sec

Back Next

FIGURE 9f

**Weekly Schedule**

▼ Select New Schedule

SaveAs Delete Modify

MON 08:00 am OCC  
---- 10:00 pm UNOCC  
TUE 08:00 am OCC  
---- 10:00 pm UNOCC  
WED 08:00 am OCC  
---- 10:00 pm UNOCC  
THU 08:00 am OCC

Back Next Download

FIGURE 9g

**Modify Schedule**

Day: ▼ Monday

Event#	-- Mode --	-- Time --
1	▼ Occupied	08:00 am
2	▼ Unoccupied	10:00 pm
3	▼ None	12:00 am
4	▼ None	12:00 am

CopyDayTo ☐ Sun ☐ Sat ☐ Hol  
☐ M ☐ T ☐ W ☐ T ☐ F

OK

FIGURE 9h

**SetPoints**

	Heating	Cooling
Occupied	70 F	75 F
Standby	67 F	78 F
UnOcc	55 F	85 F
Occupied SetPt Stops	55 F	85 F

TempOverride: ▼ 3 Hrs

Back Next Download

FIGURE 9i

Summary	
<b>Config Name:</b> ExampleModelID	
<b>Description:</b> T7350D model supports: 6 Relays,..... remote space sensor, DAT, OAT,..... RH, Occ sensor]	
<b>Model:</b>	▼ T7350D,3H3C,RH
<b>Control:</b>	Standard Heat Pmp
CnfgID	
DownLd	
Back	Next Save SaveAs

FIGURE 9j

Summary	
<b>Config Name:</b> ExampleModelID	
<b>Description:</b> T7350D model supports: 6 Relays,..... remote space sensor, DAT, OAT,..... RH, Occ sensor]	
<b>Model:</b>	▼ T7350D,3H3C,RH
<b>Control:</b>	Standard Heat Pmp
CnfgID	
DownLd	
Back	Next Save SaveAs

FIGURE 10a

File	Com	Set	Sched	Opt
Config Name		Home		
Description		Summary		
T7350D model		Inputs		
remote space		Outputs		
RH, Occ sens		Cooling		
		Heating		
<b>Model:</b>	▼	Fan		
<b>Control:</b>		SetPoints		
CnfgID		Display		
		Dehumidification		
		EnergyMgmt		
		LoopTuning		
Back	Next	Save	SaveAs	

FIGURE 10b

File	Com	Set	Sched	Opt
Config Name:	E>	Wkly Sched		
Description:		Recovery		
T7350D model sup		Holiday		
remote space sens		DayLightSav		
RH, Occ sensor				
<b>Model:</b>	▼	T7350D,3H3C,RH		
<b>Control:</b>		Standard Heat Pmp		
CnfgID				
		DownLd		
Back	Next	Save	SaveAs	

FIGURE 10c

Display	
<b>Units:</b>	F C
<b>Rm Temp:</b>	Display NoDisplay
Occupied SetPoint Stops	
Min 55	Max 85
<b>Clock:</b>	AM/PM 24 hr
<b>Key Pad:</b>	▼ Enable All
<b>SysSwitch:</b>	▼ OFF
OK	

FIGURE 10d

Dehumidification	
<b>High Limit:</b>	65 %
<b>Dehumid Options:</b>	
<input checked="" type="checkbox"/> Min ON Time	▼ 5 min
<input checked="" type="checkbox"/> Reheat	
<input checked="" type="checkbox"/> Reset Temp SetPt	1 F
Spin Speed	
OK	1X 10X

FIGURE 10e



### Energy Management

**Demand Limit**  
**Control Bump:** 3  F

**Power Failure**  
**Seq Start:**  0 sec

FIGURE 10f

### Loop Tuning

	Heating	Cooling
TR	7 <input type="text"/>	7 <input type="text"/> F
IT	1650 <input type="text"/>	1650 <input type="text"/> sec
DT	0 <input type="text"/>	0 <input type="text"/> sec
Anticipator Authority:	4 <input type="text"/> F	<input type="button" value="Apply To"/> <input type="button" value="Htg"/> <input type="button" value="Htg&amp;Clg"/>

**Spin Speed**

FIGURE 10g

### Recovery

	Cool	Heat
OAT@Min:	90 <input type="text"/>	0 <input type="text"/> F
Ramp Min:	3 <input type="text"/>	5 <input type="text"/> F/hr
OAT@Max:	70 <input type="text"/>	40 <input type="text"/> F
Ramp Max:	6 <input type="text"/>	8 <input type="text"/> F/hr

LeadTime -Cool- -Heat-  
 MaxRange 1.8 to 3.5 2.0 to 3.1 hr

FIGURE 10h

### Day Light Saving

**Start Month:**  Apr  
**Start Day:**  FirstSun

**Stop Month:**  Oct  
**Stop Day:**  LastSun

**Spin Speed**

FIGURE 10i

### Holiday

**New Years Day**  
 Jan 1, Dur:1  
 Memorial Day  
 May LastMon, Dur:1  
 Independence Day  
 Jul 4, Dur:1  
 Labor Day

FIGURE 10j

### Modify Holiday

New Years Day

**Start Month:**  Jan  
**Start Day:**  1

**Duration:** 1  Day

**Spin Speed**

FIGURE 10k




Figure 101




FIGURE 11a




FIGURE 11b




FIGURE 12a




FIGURE 12b




FIGURE 12c




FIGURE 12d




FIGURE 12e




FIGURE 13




FIGURE 14a





FIGURE 14b



Main File **Set Up** Schedule  
 Home7777  
 Thermostat  
 Configuration  
 Tool  
 File: .....  
 Config ID = 0  
 Upload Download

**Program**

Day: **Sunday** Set Points

Event #	Day	Time
1	Monday	8:30 am
2	Tuesday	5:30 pm
3	Wednesday	7:00 pm
4	Thursday	12:00 am
	Friday	
	Saturday	

Do it    1   2   3   4   5   6   7

Copy Day To: ☐ ☐ ☐ ☐ ☐ ☐ ☐

Cancel    Done

**Program**

Day: ▼ Sunday Set Points

Event#	Mode	Time
1	▼ Occupied	8:30 am
2	▼ Unocc	5:30 pm
3	▼ Standby	7:00 pm
4	▼ None	12:00 am

Do it 1 2 3 4 5 6 7

Copy Day To: ☐ ☐ ☐ ☐ ☐ ☐ ☐

Cancel Done

**Program**

Day: ▼ Sunday Set Points

Event#	Mode	Time
1	None	3:30 am
2	Occupied	5:30 pm
3	Standby	2:00 am
4	Unocc	2:00 am

Do It    1   2   3   4   5   6   7

Copy Day To: ☐ ☐ ☐ ☐ ☐ ☐ ☐

Cancel
Done

**Program**

Day: ▼ Sunday Set Points

Event#	Mode	Time
1	▼ Occupied	8:30 am
2	▼ Unocc.	5:30 pm

**Select Event Time**


8 : 3 0 ▲▼ AM PM

OK Cancel

Set Points		
	Cooling	Heating
Occupied	72	70
Standby	75	68
Unoccupied	80	60

Cancel

OK



**Installer Set Up**


Temperature Units  
☒ Deg F   ☐ Deg C

Clock Format  
☒ 12 Hr   ☐ 24 Hr

Fan Behavior  
☒ Continuous   ☐ Intermittant

Program from Keyboard  
☒ Yes   ☐ No

FIGURE 14i



**Set Up 2**


Heat Stages  
☒ 1   ☐ 2   ☐ 3

Cool Stages  
☒ 1   ☐ 2   ☐ 3

Energize Fan For  
☒ Cool Only   ☐ Heat & Cool

Sensor Location  
☒ Local   ☐ Remote

FIGURE 14j




**Load Program**

Choose File

**Standard 1**

Target  
 Wendy's 1  
 Standard 2  
 K-Mart Heatpumps  
 Pay-less Shoes

FIGURE 14k



**Select**


**Honeywell**

Thermostat  
 Configuration  
 Tool

File: Standard 1.....

Config ID = 0

FIGURE 14l



**Save to File**

Save the current Thermostat  
 configuration as file name:

.....

FIGURE 14m

**Weekly Schedule**

▼ Select New Schedule

.....

SaveAs Delete Modify

**MON 08:00 am OCC**  
 ---- 10:00 pm UNOCC  
 TUE 08:00 am OCC  
 ---- 10:00 pm UNOCC  
 WED 08:00 am OCC  
 ---- 10:00 pm UNOCC  
 THU 08:00 am OCC

Back Next Download

Figure 14n

**Holiday**

▼ Select New Holiday Group

.....

SaveAs Delete Modify

**New Years Day**  
 Jan 1, Dur:1  
 Memorial Day  
 May LastMon, Dur:1  
 Independence Day  
 Jul 4, Dur:1  
 Labor Day

OK Download

Figure 14o

**SetPoints**

	Heating	Cooling
Occupied	70	75 F
Standby	67	78 F
UnOcc	55	85 F
Occupied SetPt Stops	55	85 F

TempOverride: ▼ 3 Hrs

Back Next Download

Figure 14p

File	Com	Set	Sched	Opt
Config	Nar	Home		
Descriptia		Summary		
T7350D.moc		Inputs		
remote.spac		Outputs		
RH, Occ sens		Cooling		
		Heating		
Model:		Fan		
Control:		SetPoints		
CnfgID		Display		
		Dehumidification		
		EnergyMgmt		
		LoopTuning		

Back Next Save SaveAs

Figure 14q

**Honeywell**

**T7350 Configuration Tool**

Version: 0.0.d.18d

Override Monitor Data

Set Clock Holidays

Temp SetPts Wkly Schedule

Upload Config

New Config

▼ Select Existing Config

Figure 14r

File	Com	Set	Sched	Opt
Conf	Download	mpleModelID		
Desc	Upload			
T735	Monitor	irts, 8 Relays:		
3Htg	Set Clock	an, Sensors:		
remo	Calibrate	irture, DRT		
	Override			
Model: ▼ T735UD,3H3C,RH				
Control: <b>Standard</b> Heat Pmp				
CnfgID				
DownLd				
Back Next Save SaveAs				

Figure 14s

### Honeywell

## T7350 Configuration Tool

Version: 0.0.d.18h

Override	Monitor Data
Set Clock	Holidays
Temp SetPts	Wkly Schedule
Upload Config	
New Config	
▼ Select Existing Config	

Figure 14t

### Honeywell

## T7350 Configuration Tool

Version: 0.0.d.18h

### Override Outputs

**Please connect PDA serial port to the T7350 using the serial cable & Thermostat Interface Module.**

OK Cancel

Figure 14u

### Override

**Delays:** **ON** OFF

**ManualMode:** **Run** Manual

**Y1:** ▼ OFF **W1:** ▼ OFF

**G:** ▼ OFF **A1/W2/Y2:** ▼ OFF

**AC:** 0 % **AH:** 0 %

Spin Speed **1X** 10X

Close

Figure 14v

### Override

**Delays:** **ON** OFF

**ManualMode:** **Run** Manual

**Y1:** ▼ OFF **W1:** ▼ OFF

**Y2:** ▼ OFF **W2:** ▼ OFF

**Y3:** ▼ OFF **W3/Y4:** ▼ OFF

**G:** ▼ OFF **aux:** ▼ OFF

Close

Figure 14w

### Override

**Delays:** **ON** OFF

**ManualMode:** **Run** Manual

**Y1:** ▼ OFF **W1:** ▼ OFF

**Y2:** ▼ OFF **W2:** ▼ OFF

**Y3:** ▼ OFF **W3/Y4:** ▼ OFF

**G:** ▼ OFF **aux:** ▼ OFF

### Manual Override

Figure 14x




Figure 14y




Figure 14z






FIGURE 15




FIGURE 16




FIGURE 17




FIGURE 18




FIGURE 19




FIGURE 20a




FIGURE 20b




Figure 21








FIGURE 23




FIGURE 24




FIGURE 25a




FIGURE 25b




FIGURE 26




FIGURE 27

**Honeywell**  
T7350 Configuration Tool  
Version: diag1

Override	Monitor Data
Set Clock	Commission
Temp SetPts	Holidays
Upload Config	Wkly Schedule
New Config	

▼ Select Existing Config

FIGURE 28a

**Honeywell**  
T7350 Configuration Tool  
Version: diag1

**T7350 Online Diagnostics**

**i** Please connect PDA serial port to the T7350 using the serial cable & Thermostat Interface Module.

OK Cancel

FIGURE 28b

**Commission Summary**

**Sensors:** Failed  
**Fan/Aux:** UnTested  
**Cooling:** OK  
**Heating:** OK  
**Error Summary:**  
 DISCHARGE AIR SENSOR FAILURE:  
 Temperature sensor is configured  
 and is out of range or disconnected.  
 REMOTE OUTDOOR AIR SENSOR

Back Next Close

FIGURE 28c

**Sensors**

	Valid
RoomTemp: 73 F	<input type="checkbox"/>
Remote SetPt: -5	<input type="checkbox"/>
Remote Bypass: OFF	<input type="checkbox"/>
Room Rel Humidity: 55 %	<input type="checkbox"/>
Occupancy Sensor: OFF	<input type="checkbox"/>
Discharge Air Temp: Failed	
Outdoor Air Temp: 60 F	<input type="checkbox"/>

Back Next Update Test

FIGURE 29a

**Sensors**

	Valid
RoomTemp: 73 F	<input type="checkbox"/>
Remote SetPt: -5	<input type="checkbox"/>
Remote Bypass: OFF	<input type="checkbox"/>

**Testing Room Temp**

**? Room Temp: 73F**  
 Please confirm Room Temperature.

Pass Fail

FIGURE 29b

**Sensors**

	Valid
RoomTemp: 73 F	<input checked="" type="checkbox"/>
Remote SetPt: -5	<input type="checkbox"/>

**Testing Remote SetPt**

**? Remote SetPt: -1**  
 Please rotate remote setpoint to the full position (CCW) and tap OK.

OK

FIGURE 29c

Sensors	
RoomTemp: 73 F	Valid <input checked="" type="checkbox"/>
<b>Testing Remote SetPt</b>	
<p><b>? Full - setting validated.</b>  <b>Remote SetPt: -5</b>  <b>Please rotate remote setpoint to the full + position (CW) and tap OK.</b></p>	
<input type="button" value="OK"/>	

FIGURE 29d

Sensors	
RoomTemp: 73 F	Valid <input checked="" type="checkbox"/>
Remote SetPt: -5	<input checked="" type="checkbox"/>
<b>Testing Remote SetPt</b>	
<p><b>i Full + setting validated.</b>  <b>Remote SetPt: +5</b>  <b>Setpoint test sequence completed.</b></p>	
<input type="button" value="OK"/>	

FIGURE 29e

Sensors	
RoomTemp: 73 F	Valid <input checked="" type="checkbox"/>
Remote SetPt: -5	<input checked="" type="checkbox"/>
Remote Bypass: OFF	<input checked="" type="checkbox"/>
Room Rel Humidity: 55 %	<input checked="" type="checkbox"/>
Occupancy Sensor: OFF	<input checked="" type="checkbox"/>
Discharge Air Temp: Failed	
Outdoor Air Temp: 60 F	<input checked="" type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 29f

Fan/Auxiliary Equipment	
ManualMode: OFF	Valid
Fan - G: OFF	<input type="checkbox"/>
TimeOfDay - A1: OFF	<input type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 30

Cooling Equipment	
ManualMode: OFF	
Fan Status: OFF	Valid
Clg Stage1 - Y1: OFF	<input type="checkbox"/>
Clg Stage2 - Y2: OFF	<input type="checkbox"/>
Clg Stage3 - Y3: OFF	<input type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 31a

Cooling Equipment	
ManualMode: OFF	
Fan Status: OFF	Valid
Clg Stage1 - Y1: OFF	<input type="checkbox"/>
<b>Testing Cooling Operation</b>	
<p><b>? Fan Status: OFF</b></p> <p><b>Please confirm it is safe to start the fan.</b></p>	
<input type="button" value="Yes"/> <input type="button" value="No"/>	

FIGURE 31b

**Cooling Equipment**

ManualM de: OFF  
 Fan Status: OFF Valid  
 Clg Stage1 - Y1: OFF ☐

**Testing Cooling Operation**

? Fan Status: ON  
 Please confirm Fan operation.

Pass Fail

FIGURE 31c

**Cooling Equipment**

ManualM de: OFF  
 Fan Status: OFF Valid

**Testing Cooling Stages**

? Fan Status: ON  
 # of Stages: 0  
 Please confirm it is safe to start Cooling Stages.

Yes No

FIGURE 31d

**Cooling Equipment**

ManualMode: OFF  
 Fan Status: OFF Valid  
 Clg Stage1 - Y1: OFF ☐  
 Clg Stage2 - Y2: OFF ☐

**Testing Cooling Stages**

# of Stages: 1  
 DischargeAirT: 78F  
 CoilDeltaT: 0F  
 Progress: ||.....  
 Cancel

FIGURE 31e

**Cooling Equipment**

ManualMode: OFF  
 Fan Status: OFF Valid  
 Clg Stage1 - Y1: OFF ☐  
 Clg Stage2 - Y2: OFF ☐

**Testing Cooling Stages**

# of Stages: 1  
 DischargeAirT: 73F  
 CoilDeltaT: 5F  
 Progress: |||.....  
 Cancel

FIGURE 31f

**Cooling Equipment**

ManualMode: OFF  
 Fan Status: OFF Valid  
 Clg Stage1 - Y1: OFF ☐  
 Clg Stage2 - Y2: OFF ☐

**Testing Cooling Stages**

Validated Stage 1  
 Cooling Operation  
 Progress: |||||.....  
 Cancel

FIGURE 31g

**Cooling Equipment**

ManualMode: OFF  
 Fan Status: OFF Valid  
 Clg Stage1 - Y1: OFF ☒  
 Clg Stage2 - Y2: OFF ☒  
 Clg Stage3 - Y3: OFF ☒

Back Next Update Test

FIGURE 31h



Heating Equipment	
Manual Mode: OFF	
Fan Status: OFF	Valid
Htg Stage1 - W1: OFF	<input type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 32a

Heating Equipment	
Manual Mode: OFF	
Fan Status: OFF	Valid
<b>Testing Heating Operation</b>	
<p>❓ Fan Status: OFF</p> <p>Please confirm Fan air flow is required for stage 1 heating.</p>	
<input type="button" value="Yes"/> <input type="button" value="No"/>	

FIGURE 32b

Heating Equipment	
Manual Mode: OFF	
Fan Status: OFF	Valid
<b>Testing Heating Stages</b>	
<p>❓ Htg Stage 1: OFF</p> <p>Please confirm it is safe to activate Heating Stage contact.</p>	
<input type="button" value="Yes"/> <input type="button" value="No"/>	

FIGURE 32c

Heating Equipment	
Manual Mode: OFF	
<b>Testing Heating Stages</b>	
<p>❓ Htg Stage 1: ON</p> <p>Please confirm Heating Stage 1 operation. For example, room baseboard heat is activated.</p>	
<input type="button" value="Pass"/> <input type="button" value="Fail"/>	

FIGURE 32d

Heating Equipment	
Manual Mode: OFF	
Fan Status: OFF	Valid
Htg Stage1 - W1: OFF	<input checked="" type="checkbox"/>
<input type="button" value="Back"/> <input type="button" value="Next"/> <input type="button" value="Update"/> <input type="button" value="Test"/>	

FIGURE 32e




FIGURE 33